

## UNDERGROUND SERVICE METER RACK 200 AMP 936-544-5641

### NOTES:

1. Member will be responsible for digging ditch and installing wire in conduit with elbow. Minimum depth of 30”.
2. Co-op will furnish the Underground Meter Base and the length of wire from the transformer to the meter base. (*Maximum allowance from transformer to meter base = 250’*)
3. Member to install up to 18” above ground level with threaded nipple.

### WHAT TO DO:

- Once your trench is dug and your meter base is installed, please contact the HCEC office so that someone can measure for the length of wire. \*\*\* Leave PVC elbow exposed for servicemen to inspect.
- Our warehouse will cut the UG wire and have it available in the warehouse to pickup from 7:30 AM until 3:00 PM Mon – Fri (Customer needs to verify wire is available before traveling to warehouse)
- Member is responsible for pulling wire through pipe and making all connections in member’s meter base/breaker box. Once that is complete and outlets have been trimmed out, please call 936-544-5641 so that a serviceman can make the final connections at the transformer and install the electric meter.

*Furnished by HCEC: A maximum of 250’ of UG service wire from transformer to meter base, UG meter base, & 2 ½” conduit up the transformer pole.*

**For any questions, please contact HCEC at 936-544-5641!**

MAXIMUM UG WIRE LENGTH ALLOWED: 250’  
(FROM TRANSFORMER TO METER BASE)

